



INFORMATION NOTICE

ELECTRIC HEATING KITS



Atwood will not assume any liabilities that arise if an auxiliary heating system of any kind is attached to the Atwood furnace.

Atwood discourages, and will not assume any liabilities that arise from, the altering of any Atwood furnace to accommodate the use of any auxiliary heating system (ie. electric heating kit).

Alterations to the Atwood furnace may result in damage to components or furnace, and will void the product warranty.

Application of an electric heating kit to Atwood furnace models 8500 and 8900 Series voids the CSA listing to ANSI Z21.47b-2006, CSA 2.3b-2006, gas-fired central furnaces.

Removing the plenum and replacing with another configuration risks the functionality of the high limit switch which is critical to controlling outlet temperatures with many combinations of duct systems approved by Atwood for installation. Changing the airflow characteristics in the heat exchange plenum risks the integrity of the heat exchanger and increases the possibility for CO leakage. Additional affects include possible air flow and delivery performance degradation and improper static requirements. Atwood will not approve the use of any add-on device that is not specifically designed to meet Atwood's stringent requirements and meet ANSI Standards.

Please direct any questions regarding this notice to the Atwood Service Department at (866) 869-3118.